

Regulation DD-36.0: Emergency Lighting

- 36.1 Emergency, battery operated lighting shall be provided at entrances, escape stairways and lobbies.
Emergency power supply for these areas shall be independent of other lighting & power sources.
- 36.2 Emergency lights shall also be provided to give sufficient illumination on essential control stations for the safe operation or shut down of plant and machinery so as to avert danger in the event of a power failure.